



Heat exchangers and duct heaters are supplied with electrical control panels using Thyristor and PID thermoregulators for precision control.

Additional instrumentation for other thermal and non-thermal control requirements can be incorporated.

## Features

Designed for installation in classified area (Zone 1 and Zone 2), installed near the heater or mounted on the same structure skid.

ATEX certified T3 – T6 , Ex d IIB + H2.

Electrical protection up to IP 66.

With thermoregulator, Thyristor, contactor and local and remote control.

Pressurized control panels for hazardous areas are available.

## Certifications:

ATEX / IECEx

